Power Electronics / Installation Technique

MINISTART Softstarter With Softstop IL 9017/300


Translation of the original instructions





- According to IEC/EN 60947-4-2
- Increases life of 1-phase squirrel motors and mechanical drives
- For single phase motors up to 1.5 kW
- Adjustable ramp time/deceleration time and starting torque/ deceleration torque
- Control input for Start/Stop
- · Semiconductors will be bridged after start up
- LED indication
- Width 35 mm

Function Diagram



Connection Terminals

Terminal designation	Signal description
L1	Phase voltage L
N	Neutral
T1	Motor connection T1
T2	Motor connection T2
Q1	Control contact
Q2	Control contact

Approvals and Markings



Applications

- · Drives with gears, belts or chains
- Conveyor belts, fans
- Pumps, compressors

Function

These softstart and softstop devices are robust electronic control units for softstart and softstop of AC motors. By means of phase-angle control the current rises e. g drops continuously. The motor torque behaves in the same way during start-up e.g. deceleration. This ensures that the drive can start and stop without jerking. This eliminates the risk of damage to drive elements because the sudden starting e.g. deceleration torque does not occur during direct switch-on. This feature allows a low-cost design of the drive elements. A significant reduction in starting noise can also be observed.

In belt conveyor systems, slippage or tipping over of the conveyed material is avoided. After successful start-up, the power electronics are bridged by means of an internal relay contact in order to minimise the losses in the device.

Indicators

LED green: LED yellow: Softstart is on voltage


On, when power semiconductors is

bridged,

short flashing when mains frequency

is outside limits

Block Diagram



Notes

The speed setting of drives is not possible with these devices. Likewise, no pronounced soft starting behaviour is achieved in uncoupled state, i.e. without load. If the power semiconductor is to be protected against shortcircuit or ground fault during start-up, a semiconductor fuse (see technical data) must be used. Otherwise, the usual cable and motor protection measures must be applied. In case of high switching frequency, monitoring the winding temperature is recommended as a motor protection measure. The soft starter must not be operated with a capacitive load, such as reactive power compensation, at the output.

To ensure the safety of persons and systems, only suitably qualified personnel may work on this device.

Technical Data

AC 230 V Nominal voltage U_N: -15 % +10 %

50 / 60 Hz Nominal frequency: Nominal motor power P_N: 1.5 kW Min. motor power: Approx. 0.1 P_N Nominal current: 10 A Max. 340 A2s

Semiconductor fuse: Starting torque

20 ... 70 % deceleration torque:

Ramp-up time/

deceleration time: 0.1 ... 10 s Recovery time: 45 ms

Switching frequency: 10/h at 3 x I_r / t_{an} = 10 s, ϑ_U = 20 °C

Power consumption: 1.4 VA

Short circuit strength

25 A gG / gL IFC/FN 60947-5-1 Max. fuse rating: Assignment type:

Electrical life: > 10 x 10⁶ switching cycles

General Data

Operating mode: Continuous operation

Temperature range Operation: 0 ... + 55 °C Storage: - 25 ... + 75 °C Relative air humidity: 93% at 40°C < 1000 m Altitude:

Clearance and creepage

distances

Overvoltage category: Ш

Rated impulse voltage /

pollution degree: 4 kV / 2 IEC 60664-1 **EMC**

Interference resistance

8 kV (air) IEC/EN 61000-4-2 Electrostatic discharge:

HF irradiation 80 Mhz ... 1.0 GHz: 10 V/m IEC/EN 61000-4-3 1.0 GHz ... 2.5 GHz: 3 V/m IEC/EN 61000-4-3 2.5 GHz ... 2.7 GHz: 1 V/m IEC/EN 61000-4-3 Fast transients: 2 kV IEC/EN 61000-4-4

Surge voltages

Vibration resistance:

between wires for power supply: 1 kV IEC/EN 61000-4-5

IEC/EN 61000-4-5 between wire and ground: 2 kV HF wire guided: 10 V IEC/EN 61000-4-6

Interference emission Limit value class B IFC/FN 60947-4-2 Wire guided:

Radio irradiation: Limit value class B IEC/EN 60947-4-2 Degree of protection

IP 40 Housing: IEC/EN 60529 Terminals: IP 20 IEC/EN 60529

Thermoplastic with V0 behaviour Housing: according to UL subject 94

Amplitude 0.35 mm, IEC/EN 60068-2-6

frequency 10 ... 55 Hz

0 / 055 / 04 IEC/EN 60068-1 Climate resistance:

Terminal designation: EN 50005

Wire connection: 2 x 2.5 mm² solid or 2 x 1.5 mm² stranded ferruled

DIN 46228-1/-2/-3

Stripping length: Max. 10 mm

Wire fixing: Flat terminals with self-lifting

clamping piece IEC/EN 60999-1

Fixing torque: Max. 0.8 Nm

Technical Data

DIN rail IEC/EN 60715 Mounting: Weight: 135 g

Dimensions

35 x 90 x 61 mm Width x height x depth:

Standard Type

IL 9017/300 AC 230 V 1.5 kW

0058831 Article number: Nominal voltage U_N: AC 230 V

For motors up to 1.5 kW

Width: 35 mm

Setting Facilities

Ramp up/deceleration time: With potentiometer toneff the ramp up and decelertion time can be adjusted within the range 0.1 to 10 s. Starting and deceleration torque: With potentiometer $M_{on.off}$ the starting torque and the deceleration torque can be adjusted in the range of 20 to 70 % of the max. value.

Set-up Procedure

- Set potentiometer "M_{on, off}" fully anti-clockwise Set potentiometer "t_{on, off} fully clockwise
- Start motor by closing contact input Q1-Q2. If the motor does not start, interrupt the process and adjust " $M_{\text{on,off}}$ " to a higher value. New
- 3. Adjust potentiometer " $t_{on, off}$ " to give the desired ramp time. Stop and restart the motor, readjusting the potentiometers until the desired starting characteristics are achieved.

Attention:

If the ramp-up time is adjusted to short, the internal bridging contact closes before the motor is on full speed. This may damage the bridging relay.

Changes on potentiometer settings are only accepted in

the waiting for start status.

Application Example

